

75
आजादी का
अमृत महोत्सव
2-151

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 527

Dated: 22/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Red Roses Public School** located at D-Block, Saket, New Delhi-110017 comprised of Ground + Three upper floors owned/occupied by Shri R. R. Mehta Educational Trust (Regd.) was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/SZ/149 dated 10-02-2022. The premises was re-inspection by officer concerned by this department on 17/04/2025 in the presence of Dr. Anuradha Mehta (Principal) of the school and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group-B "Educational Building" with effect from 22/04/2025 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 22/04/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Red Roses Public School located at D-Block, Saket, New Delhi-110017
2. The Directorate of Education, MCD, Dr. SPM Civic Centre, Minto Road, Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

Principal
Red Roses Public School
(CBSE Affiliated Senior Secondary School)
D-Block, Saket
New Delhi - 110017
CBSE Affiliation No. 2730194